



DECLARATION OF PERFORMANCE (DoP)

No: DoP – 0001-2021

1. Unique product-type identification code: **Electric cable type H05VV-F 380/660 V**
2. Type, batch or serial number: H05VV-F 380/660 V – 2x0,75 (6,31); 2x1,0 (6,79); 2x1,5 (7,80); 2x2,5; (9,47)
H05VV-F 380/660 V – 3x0,75 (6,75); 3x1,0 (7,15); 3x1,5 (8,42); 3x2,5 (10,00)
H05VV-F 380/660 V – 4x0,75 (7,24); 4x1,0 (7,97); 4x1,5 (9,15); 4x2,5 (10,92)
H05VV-F 380/660 V – 5x0,75 (8,29); 5x1,0 (8,66); 5x1,5 (10,16); 5x2,5 (12,14)
3. Intended use of construction product: Supply of electricity in residential buildings or other civil constructions, subject to fire reaction regulation
4. Manufacturer: **“Rybinskij elektromontazhnyj zavod” Ltd**
Yaroslavsky tract, 68, Rybinsk, Russian Federation.
Reg. (TNN) No. 7610077208
Tel.: +7 4855202600; E-mail: info@remz.su
5. Official representative in EU **NEWVIDA FINANCE LTD**
Valdouinou 25 Limassol 4152 Kato Polemidia, CYPRUS
Tel.: +372 5714 0000; E-mail: newvida.finance@gmail.com
6. AVCP system: **System 3**
7. In case of the declaration of performance concerning a construction product covered by a harmonized standard: In accordance with requirements of the harmonized standard EN 50575:2015-03/A1:2016-11 “Power, control and communication cables - Cables for general applications in construction works subject to reaction to fire requirements” and also with Annex V of the CPR 305/2011 on base of Reports Ref.:
– *Test and Conformity of Performance Report No. LZP01-00744/21/Z00NZPE and No. LZP02-00744/21/Z00NZPE issued 23.02.2021 according to EN 60332-1-1:2010/A1:2016+A11:2017*
– *Classification Report Reaction to Fire of Cables No. 00744.1/21/Z00NZP issued 05.03.2021 according to EN 13501-6:2019 and in accordance with EXAP PD CLC/TS 50576:2016*
by European Notified Body No. 1488 Fire Research Department, Building Research Institute, Filtrowa str. 1, 00-611, Warszawa.
8. Declared performance:

| Essential characteristics | Performance | Harmonised technical specification |
|---------------------------|---|---|
| Reaction to fire | Eca | EN 50575:2015-03/A1:2016-11, PD CLC/TS 50576:2016 |
| RoHS II-III compliance | Meets the requirements of Directives 2011/65/EC and 2015/863/EU | |

9. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 8. This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer by :

Mr. Sergey Yurevich Kuzenyov
The General Director of “Rybinskij
elektromontazhnyj zavod” Ltd
Rybinsk, Russia 15/03/2021

.....
Issue place and date





“Rybinskij elektromontazhnyj zavod” Ltd.
Yaroslavsky tract, 68, Rybinsk, Russian Federation.
Reg. (TNN) No. 7610077208
Tel.: +7 4855202600; E-mail: info@remz.su

21

EN 50575:2015/A1:2016 “Power, control and communication cables - Cables for general applications in construction works subject to reaction to fire requirements”

Electric cables type NYIFY-O 0,6/1 kV – 2x1,5 (4,55; 7,11)

Supply of electricity in residential buildings or other civil constructions, subject to fire reaction regulation

Reaction to fire: Eca

Meets the requirements of Directives 2011/65/EC and 2015/863/EU

Similar marking for all other cables denominations NYIFY-O 0,6/1 kV

Аналогичная маркировка для всех прочих номиналов кабелей NYIFY-O 0,6/1 kV

